

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No .:	IECEx DEK 12.0059	Page 1 of 5	Certificate history:
Status:	Current	Issue No: 2	Issue 1 (2016-08-02) Issue 0 (2012-12-18)
Date of Issue:	2021-07-02		
Applicant:	Knick Elektronische Messgeräte GmbH & C Beuckestrasse 22 D-14163 Berlin Germany	o. KG	
Equipment:	Measuring System Type Portavo 90*X*		
Optional accessory:			
Type of Protection:	Ex ia		
Marking:	Ex ia IIC T4/T3 Ga		
Approved for issue o Certification Body: Position:	n behalf of the IECEx	R. Schuller Certification Manager	
Signature:		Bluth	
(for printed version)			
Date:		2021-07-02	
This certificate is not	chedule may only be reproduced in full. transferable and remains the property of the issuing body. enticity of this certificate may be verified by visiting www.ie	cex.com or use of this QR Code.	
Certificate issued	-		
DEKRA Certifica Meander 1051 6825 MJ Arnhen Netherlands			DEKRA



Certificate No .:	IECEx DEK 12.0059	Page 2 of 5			
Date of issue:	2021-07-02	Issue No: 2			
Manufacturer:	Knick Elektronische Messgeräte GmbH & Co. KG Beuckestrasse 22 D-14163 Berlin Germany				
Additional manufacturing locations:					
This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended					
STANDARDS : The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards					
IEC 60079-0:2017 Edition:7.0	Explosive atmospheres - Part 0: Equipment - General requirements				
IEC 60079-11:2011 Edition:6.0	Explosive atmospheres - Part 11: Equipment protection by intrinsi	ic safety "i"			
	This Certificate does not indicate compliance with safety and	performance requirements			

his Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

NL/DEK/ExTR12.0061/02

Quality Assessment Report:

DE/TUN/QAR06.0016/10



Certificate No .:

IECEx DEK 12.0059

2021-07-02

Page 3 of 5

Date of issue:

Issue No: 2

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

The Measuring System Type Portavo 90*X* is a battery powered hand-held electrical equipment for pH, conductivity and temperature measurement for analog or digital sensors. The USB interface is only for use outside of the explosion hazardous area.

The ambient temperature range and temperature class depends on the batteries used as follows:

Battery:	Ambient temperature range:	Temperature class:
Duracell MN1500	-10 °C to +40 °C	T4
Energizer E91	-10 °C to +50 °C	T3
Power One 4106	-10 °C to +50 °C	Т3
Panasonic Pro Power LR6	-10 °C to +50 °C	T3

SPECIFIC CONDITIONS OF USE: NO



Certificate No.:

IECEx DEK 12.0059

Page 4 of 5

Date of issue:

2021-07-02

Issue No: 2

Equipment (continued):

Electrical data

Supply	Only the following batteries may be used: Duracell MN1500 Energizer E91 Power One 4106 Panasonic Pro Power LR6 in type of protection intrinsic safety Ex ia IIC, with the following maximum values:						
	U ₀ (V)	I ₀ (mA)	P _o (mW)	C _o (µF)	L _o (mH)		
pH-Measuring circuit(MEAS)	4.1	0.1	0.1	100	1000	Linear characteristic	
Temperature measurement circuit(TEMP1, TEMP2)	4.1	4.4	4.6	99	1000	Linear characteristic	
pH / Temperature measurement circuit (MEAS, TEMP1, TEMP2)	7.2	4.4	4.6	13.3	1000	Linear characteristic	
Conductivity measurement circuit(MEAS)	7.2	36	36.9	13.4	27	Linear characteristic	
Conductivity / Temperature measurement circuit (MEAS, TEMP1, TEMP2)	7.2	40.6	41.7	13.3	22	Linear characteristic	
Memosens interface circuit(MS and/or MEAS)	4.6	113	130	96	2.8	Linear characteristic	
USB Interface(micro USB-B) Um = 250 V							

Installation instructions

The instructions and the control drawing provided with the equipment shall be followed in detail to assure safe operation.



Certificate No.:

Date of issue:

IECEx DEK 12.0059

Page 5 of 5

2021-07-02

Issue No: 2

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)

Assessed per 60079-0 Ed. 7
Minor constructional changes