

# CERTIFICATE OF CONFORMITY



1. **HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS**
2. **Certificate No:** FM19CA0127X
3. **Equipment:** Protos Type 3400X and Protos II Type 4400X  
**(Type Reference and Name)** Modular Measuring System
4. **Name of Listing Company:** Knick Elektronische Messgeräte GmbH & Co. KG
5. **Address of Listing Company:** Beuckestrasse 22  
Berlin  
D-14163  
Germany
6. The examination and test results are recorded in confidential report number:  
  
PR455159 (supplement to 3023762) dated 1<sup>st</sup> December 2020
7. FM Approvals LLC, certifies that the equipment described has been found to comply with the following Approval standards and other documents:  
  
CSA-C22.2 No. 0:2011, CSA-C22.2 No. 213:2017, CSA C22.2 No. 142-M1987:2014,  
CAN/CSA 60079-0:2019, CAN/CSA 60079-7:2016, CAN/CSA 60079-11:2014, CAN/CSA 60079-18:2016,  
CSA C22.2 No. 94-M91: 2011, CAN/CSA C22.2 No. 60529-05:2010
8. If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to specific conditions of use specified in the schedule to this certificate.
9. This certificate relates to the design, examination and testing of the products specified herein. The FM Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved.
10. Equipment Ratings:  
  
**Protos Type 3400X and Protos II Type 4400X:**  
Ta = -20°C to 50°C; Enclosure Type 4X, IP65  
Refer to control drawing 201.003-170 for entity / nonincendive field wiring parameters

## Certificate issued by:



J.E. Marquedant  
VP, Manager - Electrical Systems

16 November 2021

Date

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

FM Approvals LLC, 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA  
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: [information@fmapprovals.com](mailto:information@fmapprovals.com) [www.fmapprovals.com](http://www.fmapprovals.com)

# SCHEDULE



Canadian Certificate Of Conformity No: FM19CA0127X

## **Modular Measuring System.**

Class I, Zone 1, Ex eb ib mb [ia Ga] IIC T4 Gb

Nonincendive, Class I, Division 2, Groups ABCD, T4 Ta = 50°C;

Nonincendive, Class II, III, Division 2, Groups EFG, T70°C Ta = 50°C;

Nonincendive, Class I, Division 2, Groups ABCD, T4 Ta = 50°C; nonincendive field wiring;

Nonincendive, Class II, III, Division 2, Groups EFG, T70°C Ta = 50°C; nonincendive field wiring;

## **or with ZU1042**

Class I, Zone 2, Ex ec ib mb [ia Ga] IIC T4 Gc

Nonincendive, Class I, Division 2, Groups T4 Ta = 50°C;

Nonincendive, Class II, III, Division 2, Groups EFG, T70°C Ta = 50°C;

## **Module Outputs**

Class I, Zone 1, Ex ib [ia Ga] IIC T4 Gb

or

Class I, Zone 1, Ex ib IIC T4 Gb

Intrinsically safe connections for Class I, II, III, Division 1, Groups ABCDEFG;

or

Nonincendive, Class I, Division 2, Groups ABCD, T4 Ta = 50°C; nonincendive field wiring;

Nonincendive, Class II, III, Division 2, Groups EFG, T70°C Ta = 50°C; nonincendive field wiring;

**The Protos Type 3400X and Protos II Type 4400X Modular Measuring System consists of the following modules:**

## **BASE 3400Xa/b or BASE 4400Xa/b. Power Supply.**

a = Enclosure material C or S;

b = Power supply option 24V or VPW

Class I, Zone 1, Ex eb ib mb IIC T4 Gb

Nonincendive, Class I, Division 2, Groups ABCD, T4 Ta = 50°C;

Nonincendive, Class II, III, Division 2, Groups EFG, T70°C Ta = 50°C;

Nonincendive, Class I, Division 2, Groups ABCD, T4 Ta = 50°C; nonincendive field wiring;

Nonincendive, Class II, III, Division 2, Groups EFG, T70°C Ta = 50°C; nonincendive field wiring;

## **or with ZU1042**

Class I, Zone 2, Ex ec ib mb IIC T4 Gc

Nonincendive, Class I, Division 2, Groups ABCD, T4 Ta = 50°C;

Nonincendive, Class II, III, Division 2, Groups EFG, T70°C Ta = 50°C;

## **FRONT 3400Xa-015 or FRONT 4400Xa-015. Door.**

a = Enclosure finish C or S.

Class I, Zone 1, Ex eb ib IIC T4 Gb

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

# SCHEDULE



Canadian Certificate Of Conformity No: FM19CA0127X

Nonincendive, Class I, Division 2, Groups ABCD, T4 Ta = 50°C; nonincendive field wiring;  
Nonincendive, Class II, III, Division 2, Groups EFG / T70°C Ta = 50°C; nonincendive field wiring;

## **Measuring Modules:**

**pH 3400X-03a. pH Module.**

a = pH measurement option 2, 3, 5 or 6

**CO2 3400X-130. Carbon Dioxide Module.**

**COND 3400X-041. Conductivity Module.**

**OXY 3400X-06a. Oxygen Module.**

a = Application option 2, 3, 5, 6 or 7

**FIU 3400X-140-2. Digital Module.**

**PHU 3400X-110. pH Module.**

**CONDI 3400X-051. Inductive Conductivity Module.**

**COMPA 3400X-081. Interface Module.**

**COMFF 3400X-085. Interface Module.**

**MS 3400X-160. Digital Module.**

**MS 4400X-160. Digital Module.**

Class I, Zone 1, Ex ib [ia Ga] IIC T4 Gb

Intrinsically safe connections for Class I, II, III, Division 1, Groups ABCDEFG;

Nonincendive, Class I, Division 2, Groups ABCD, T4 Ta = 50°C; Nonincendive field wiring;

Nonincendive, Class II, III, Division 2, Groups EFG, T70°C Ta = 50°C; Nonincendive field wiring;

## **Communication Modules:**

**OUT 3400X-071. Output Module.**

**PID 3400X-121. PID Controller Module.**

Class I, Zone I, Ex ib IIC T4 Gb

Nonincendive, Class I, Division 2, Groups ABCD, T4 Ta = 50°C; Nonincendive field wiring;

Nonincendive, Class II, III, Division 2, Groups EFG, T70°C Ta = 50°C; Nonincendive field wiring;

11. The marking of the equipment shall include:

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA



T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: [information@fmaprovals.com](mailto:information@fmaprovals.com) [www.fmaprovals.com](http://www.fmaprovals.com)

# SCHEDULE





Canadian Certificate Of Conformity No: FM19CA0127X


BASE 3400X \*/VPW:

**Knick** > **Protos**<sup>®</sup>   0044



Type 3400X \*/VPW No. 1234567

Power 100 to 230 V AC / 15 VA, 48 to 62 Hz  
- 20 ≤ Tamb ≤ +50 °C



No. 12345 / 1234567 / JJWW  14163 Berlin  
01 Made in Germany 



 FM19US0234X FM19CA0127X  
Class I, Zone 1, Ex/AEx eb ib mb [ia Ga] IIC T4 Gb  
ZU1042: Class I, Zone 1, Ex/AEx ec ib mb [ia Ga] IIC T4 Gc  
NI Class I, Division 2, Groups ABCD T4  
NI Class II, III, Division 2, Groups EFG T70°C  
including nonincendive field wiring  
IS Class I, II, III, Division 1, Groups ABCDEFG  
associated apparatus / appareillage associé  
Enclosure NEMA 4X, IP65 Control Drawing 201.003-170

BASE 3400X \*/24V:

**Knick** > **Protos**<sup>®</sup>   0044

Type 3400X \*/24V No. 1234567

Power 24 V AC/DC ~, <15 VA, 48 to 62 Hz, <10 W  
- 20 ≤ Tamb ≤ +50 °C  

No. 12345 / 1234567 / JJWW  14163 Berlin  
01 Made in Germany 

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: [information@fmaprovals.com](mailto:information@fmaprovals.com) [www.fmaprovals.com](http://www.fmaprovals.com)

# SCHEDULE



Canadian Certificate Of Conformity No: FM19CA0127X



**FM19US0234X FM19CA0127X**  
Class I, Zone 1, Ex/AEx eb ib mb [ia Ga] IIC T4 Gb  
ZU1042: Class I, Zone 1, Ex/AEx ec ib mb [ia Ga] IIC T4 Gc  
NI Class I, Division 2, Groups ABCD T4  
NI Class II,III, Division 2, Groups EFG T70°C  
including nonincendive field wiring  
IS Class I,II,III, Division 1, Groups ABCDEFG  
associated apparatus / appareillage associé

Enclosure NEMA 4X, IP65

Control Drawing 201.003-170

FRONT 3400X\*-015:

**Knick** >

**Protos® Front**

Type Front 3400X\*-015

No. 0000000

No. 00000 / 0000000 / JJWW

14163 Berlin

Made in Germany



**KEMA 03 ATEX 2530**

**IECEx DEK 11.0054**

Ex eb ib IIC T4 Gb

Ex ib tb IIIC T70°C Db



Enclosure NEMA 4X, IP65

-20 ≤ Tamb ≤ +50 °C

**FM19US0234X FMCA0127X**

Control drawing 201.003-170

Class I, Zone 1, Ex/AEx eb ib IIC T4 Gb

NI Class I, Division 2, Groups ABCD T4

NI Class II,III, Division 2, Groups EFG T70°C

including nonincendive field wiring

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA




T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: [information@fmaprovals.com](mailto:information@fmaprovals.com) [www.fmaprovals.com](http://www.fmaprovals.com)

# SCHEDULE



Canadian Certificate Of Conformity No: FM19CA0127X



BASE 4400X\*/VPW:



**Knick** > **Protos II**   0044 

Type 4400X\*/VPW No. 1234567

Power 100 to 230 V AC / 15 VA, 48 to 62 Hz  
- 20 ≤ T<sub>amb</sub> ≤ +50 °C

No. 00000 / 0000000 / JJWW




 

 01 14163 Berlin  
Made in Germany 



FM19US0234X FM19CA0127X  
Class I, Zone 1, Ex/AEx eb ib mb [ia Ga] IIC T4 Gb  
ZU1042: Class I, Zone 1, Ex/AEx ec ib mb [ia Ga] IIC T4 Gc  
NI Class I, Division 2, Groups ABCD T4  
NI Class II, III, Division 2, Groups EFG T70°C  
including nonincendive field wiring  
IS Class I, II, III, Division 1, Groups ABCDEFG  
associated apparatus / appareillage associé  
Enclosure NEMA 4X, IP65 Control Drawing 201.003-170



BASE 4400X\*/24V:



**Knick** > **Protos II**   0044 

Type 4400X\*/24V No. 1234567

Power 24 V AC/DC ~, <15 VA, 48 to 62 Hz, <10 W  
- 20 ≤ T<sub>amb</sub> ≤ +50 °C

No. 00000 / 0000000 / JJWW

 01 14163 Berlin  
Made in Germany 

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

FM Approvals LLC, 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: [information@fmaprovals.com](mailto:information@fmaprovals.com) [www.fmaprovals.com](http://www.fmaprovals.com)

# SCHEDULE



Canadian Certificate Of Conformity No: FM19CA0127X



**FM19US0234X FM19CA0127X**  
Class I, Zone 1, Ex/AEx eb ib mb [ia Ga] IIC T4 Gb  
ZU1042: Class I, Zone 1, Ex/AEx ec ib mb [ia Ga] IIC T4 Gc  
NI Class I, Division 2, Groups ABCD T4  
NI Class II,III, Division 2, Groups EFG T70°C  
including nonincendive field wiring  
IS Class I,II,III, Division 1, Groups ABCDEFG  
associated apparatus / appareillage associé

Enclosure NEMA 4X, IP65 Control Drawing 201.003-170


FRONT 4400X\*-015:


**Knick** > **Protos II Front**


Type	Front 4400X*-015
No.	0000000



14163 Berlin  
Made in Germany


No. 00000 / 0000000 / JJWW



 **KEMA 03 ATEX 2530**  
**IECEX DEK 11.0054**  
Ex eb ib IIC T4 Gb  
Ex ib tb IIIC T 70 °C Db

 0044

 Enclosure NEMA 4X, IP65  
-20 ≤ Tamb ≤ +50 °C

**FM19US0234X FMCA0127X**  
Control drawing 201.003-170  
Class I, Zone 1, Ex/AEx eb ib IIC T4 Gb  
NI Class I, Division 2, Groups ABCD T4  
NI Class II,III, Division 2, Groups EFG T70°C  
including nonincendive field wiring

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA  
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: [information@fmaprovals.com](mailto:information@fmaprovals.com) [www.fmaprovals.com](http://www.fmaprovals.com)









Member of the FM Global Group

### Measuring Modules: Protos pH3400X-033:

### Protos pH3400X-035:

### Protos Cond 3400X-041:

<b>Knick</b> > <b>Protos® Module</b> <div> Type Cond3400X-041  No. </div>	<b>COND</b> <b>Conductivity / °C</b>	<b>CE</b> 0044 -20 ≤ T <sub>amb</sub> ≤ +50 °C 14163 Berlin Made in Germany	<div>  II 2 (1) G II 2 (1) D </div>
<b>KEMA 03 ATEX 2530</b> <b>IECEx DEK 11.0054</b> Ex ib [Ia Ga] IIC T4 Gb Ex ib [Ia Da] IIIC T 70 °C Db	<div>  </div> <b>FM19US0234X FM19CA0127X</b> Control Drawing 201.003-170 Class I, Zone 1, Ex/AEx ib [Ia Ga] IIC T4 Gb IS Class I, II, III, Division 1, Groups ABCDEFG associated apparatus / appareillage associé NI Class I, Division 2, Groups ABCD T4 NI Class II, III, Division 2, Groups EFG T70 °C nonincendive field wiring		<div>    </div>
<div>  </div> <b>Cert. No. GYJ20.1054</b>			<div>  </div>





FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA  
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: [information@fmapprovals.com](mailto:information@fmapprovals.com) [www.fmapprovals.com](http://www.fmapprovals.com)



Member of the FM Global Group

Member of the FM Global Group

<b>Knick</b>	<b>Protos® Module</b>		
Type Oxy3400X-067	<b>ISM OXY</b>	-20 ≤ Tamb ≤ +50 °C 14163 Berlin Made in Germany	
No.	<div style="display: flex; justify-content: space-between;"> <div style="width: 20%;"> </div> <div style="width: 60%;"> <b>FM19US0234X FM19CA0127X</b>            Control Drawing 201.003-170  <b>Class I, Zone 1, Ex/AEx Ib [Ia Ga] IIC T4 Gb</b>  <b>IS Class I, II, III, Division 1, Groups ABCDEFG</b>  <b>associated apparatus / appareillage associé</b>  <b>NI Class I, Division 2, Groups ABCD T4</b>  <b>NI Class II, III, Division 2, Groups EFG T70°C</b>  <b>nonincendive field wiring</b> </div> <div style="width: 20%; text-align: right;">    </div> </div>		
<b>Cert. No. GYJ20.1054</b>			

<p><b>KEMA 03 ATEX 2530</b>  <b>IECEx DEK 11.0054</b></p> <p>Ex ib [Ia Ga] IIC T4 Gb          Ex Ib [Ia Da] IIIC T 70 °C Db</p> <hr/> <p> Cert. No. GYJ20.1054</p>	<p align="center"></p> <p align="center"><b>FM19US0234X FM19CA0127X</b>  <b>Control Drawing 201.003-170</b></p> <p><b>Class I, Zone 1, Ex/AEx Ib [Ia Ga] IIC T4 Gb</b>  <b>IS Class I,II,III, Division 1, Groups ABCDEFG</b>  <b>associated apparatus / appareillage associé</b>  <b>NI Class I, Division 2, Groups ABCD T4</b>  <b>NI Class II,III, Division 2, Groups EFG T70°C</b>  <b>nonincendive field wiring</b></p>	<p align="right">    </p>
---	--	---

**Knick** > **Protos® Module** **CE** <sub>0044</sub> **Ex** <sub>II 2 (1) G</sub> <sub>II 2 (1) D</sub>

Type PHU 3400X-110 **pH** **PHU**  
 No. **Unical®/Uniclean**  $-20 \leq T_{amb} \leq +50^{\circ}C$   
 14163 Berlin Made in Germany

**KEMA 03 ATEX 2530**  
**IECEx DEK 11.0054**  
 Ex Ib [Ia Ga] IIC T4 Gb  
 Ex Ib [Ia Da] IIIC T 70 °C Db

**FM** **FM19US0234X FM19CA0127X**  
**APPROVED** **Control Drawing 201.003-170**  
 Class I, Zone 1, Ex/AEx Ib [Ia Ga] IIC T4 Gb  
 IS Class I,II,III, Division 1, Groups ABCDEFG  
 associated apparatus / appareillage associé  
 NI Class I, Division 2, Groups ABCD T4  
 NI Class II,III, Division 2, Groups EFG T70°C  
 nonincendive field wiring






**Pre** **Cert. No. GYJ20.1054**

Page 9 of 13






# SCHEDULE

Canadian Certificate Of Conformity No: FM19CA0127X






Protos Condi 3400X-051:

<b>Knick &gt; Protos® Module</b>		<b>CE</b> 0044	<b>Ex</b> II 2 (1) G II 2 (1) D	 No. 665870000000JWW
Type Condi 3400X-051 No. <input type="text"/>		<b>CONDI</b> inductive Conductivity / °C -20 ≤ Tamb ≤ +50 °C 14163 Berlin Made in Germany		
KEMA 03 ATEX 2530 IECEx DEK 11.0054 Ex Ib [Ia Ga] IIC T4 Gb Ex Ib [Ia Da] IIIC T 70 °C Db		 FM19US0234X FM19CA0127X Control Drawing 201.003-170 Class I, Zone 1, Ex/AEx Ib [Ia Ga] IIC T4 Gb IS Class I, II, III, Division 1, Groups ABCDEFG associated apparatus / appareillage associé NI Class I, Division 2, Groups ABCD T4 NI Class II, III, Division 2, Groups EFG T70 °C nonincendive field wiring		 
 Cert. No. GYJ20.1054				

Protos COMPA3400X-081:

<b>Knick &gt; Protos® Module</b>		<b>CE</b> 0044	<b>Ex</b> II 2 (1) G II 2 (1) D	 No. 671340000000JWW
Type COMPA3400X-081 No. <input type="text"/>		<b>COMPA</b> Profibus PA -20 ≤ Tamb ≤ +50 °C 14163 Berlin Made in Germany		
KEMA 03 ATEX 2530 IECEx DEK 11.0054 Ex Ib [Ia Ga] IIC T4 Gb Ex Ib [Ia Da] IIIC T 70 °C Db		 FM19US0234X FM19CA0127X Control Drawing 201.003-170 Class I, Zone 1, Ex/AEx Ib [Ia Ga] IIC T4 Gb IS Class I, II, III, Division 1, Groups ABCDEFG associated apparatus / appareillage associé NI Class I, Division 2, Groups ABCD T4 NI Class II, III, Division 2, Groups EFG T70 °C nonincendive field wiring		 
 Cert. No. GYJ20.1054				

Protos COMFF3400X-085:

<b>Knick &gt; Protos® Module</b>		<b>CE</b> 0044	<b>Ex</b> II 2 (1) G II 2 (1) D	 No. 709530000000JWW
Type COMFF3400X-085 No. <input type="text"/>		<b>COMFF</b> FIELDBUS -20 ≤ Tamb ≤ +50 °C 14163 Berlin Made in Germany		
KEMA 03 ATEX 2530 IECEx DEK 11.0054 Ex Ib [Ia Ga] IIC T4 Gb Ex Ib [Ia Da] IIIC T 70 °C Db		 FM19US0234X FM19CA0127X Control Drawing 201.003-170 Class I, Zone 1, Ex/AEx Ib [Ia Ga] IIC T4 Gb IS Class I, II, III, Division 1, Groups ABCDEFG associated apparatus / appareillage associé NI Class I, Division 2, Groups ABCD T4 NI Class II, III, Division 2, Groups EFG T70 °C nonincendive field wiring		 
 Cert. No. GYJ20.1054				

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**






FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: [information@fmaprovals.com](mailto:information@fmaprovals.com) [www.fmaprovals.com](http://www.fmaprovals.com)






# SCHEDULE

Canadian Certificate Of Conformity No: FM19CA0127X






MS3400X-160:

<b>Knick &gt; Protos® Module</b>		<b>CE</b> 0044	<b>Ex</b> II 2 (1) G II 2 (1) D	 No. 78257/0000000000/jvw 01
Type MS3400X-160	<b>MS</b>	Tamb: -20 to +50 °C		
No.	<b>Memosens</b>	14163 Berlin Made in Germany		
<b>KEMA 03 ATEX 2530</b> <b>IECEX DEK 11.0054</b> Ex ib [Ia Ga] IIC T4 Gb Ex ib [Ia Da] IIIC T 70 °C Db		 FM19US0234X FM19CA0127X Control Drawing 201.003-170 Class I, Zone 1, Ex/AEx ib [Ia Ga] IIC T4 Gb IS Class I, II, III, Division 1, Groups ABCDEFG associated apparatus / appareillage associé NI Class I, Division 2, Groups ABCD T4 NI Class II, III, Division 2, Groups EFG T70°C nonincendive field wiring		 
 Cert. No. GYJ20.1054				

MS4400X-160:

<b>Knick &gt; Protos II Module</b>		<b>CE</b> 0044	<b>Ex</b> II 2 (1) G II 2 (1) D	 No. 00000/0000000000/jvw 01
Type MS 4400X-160	<b>MS</b>	-20 ≤ Tamb ≤ +50 °C		
No. 0000000	<b>Memosens</b>	14163 Berlin Made in Germany		
<b>KEMA 03 ATEX 2530</b> <b>IECEX DEK 11.0054</b> <input type="checkbox"/> Ex ib [Ia Ga] IIC T4 Gb <input type="checkbox"/> Ex ib [Ia Da] IIIC T 70 °C Db		 FM19US0234X FM19CA0127X Control Drawing 201.003-170 Class I, Zone 1, AEx/Ex ib [Ia Ga] IIC T4 Gb IS Class I, II, III, Division 1, Groups ABCDEFG associated apparatus / appareillage associé NI Class I, Division 2, Groups ABCD T4 NI Class II, III, Division 2, Groups EFG T70°C nonincendive field wiring		 
 Cert. No. GYJ20.1054				

Communication Modules:  
Protos PID3400X-121:

<b>Knick &gt; Protos® Module</b>		<b>CE</b> 0044	<b>Ex</b> II 2 G II 2 D	 No. 66591/0000000000/jvw 01
Type PID3400X-121	<b>PID</b>	-20 ≤ Tamb ≤ +50 °C		
No.	<b>Controller</b>	14163 Berlin Made in Germany		
<b>KEMA 03 ATEX 2530</b> <b>IECEX DEK 11.0054</b> Ex ib IIC T4 Gb Ex ib IIIC T 70 °C Db		 FM19US0234X FM19CA0127X Control Drawing 201.003-170 Class I, Zone 1, Ex/AEx ib IIC T4 Gb NI Class I, Division 2, Groups ABCD T4 NI Class II, III, Division 2, Groups EFG T70°C nonincendive field wiring		 
 Cert. No. GYJ20.1054				

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

# SCHEDULE



Canadian Certificate Of Conformity No: FM19CA0127X

Protos OUT3400X-071:

<b>Knick</b> ➤ <b>Protos® Module</b>		<b>CE</b> 0044	<b>Ex</b> II 2 G II 2 D
Type OUT 3400X-071	<b>OUT</b>	-20 ≤ Tamb ≤ +50 °C	
No.	analog / digital	14163 Berlin Made in Germany	
<b>KEMA 03 ATEX 2530</b> <b>IECEX DEK 11.0054</b> Ex Ib IIC T4 Gb Ex Ib IIIC T 70 °C Db	<b>FM19US0234X FM19CA0127X</b> Control Drawing 201.003-170 Class I, Zone 1, Ex/AEx Ib IIC T4 Gb NI Class I, Division 2, Groups ABCD T4 NI Class II,III, Division 2, Groups EFG T70°C nonincendive field wiring		
<b>Cert. No. GYJ20.1054</b>	No. 66590/000000/06599 No. 01		

## 12. Description of Equipment:

**General** – The Protos Type 3400X and Protos II Type 4400X modular process analysis system is intended to measure and process electrochemical quantities in liquids. It has a modular design and consists of the BASE power supply unit, the FRONT door and different measuring and communication modules.

**Construction** – Enclosures are of stainless steel with a rating of Type 4X and IP65.

**Ratings** - The equipment operates from a supply voltage of 100 to 230 V ac and dissipates 15 VA. The manufacturer specifies an ambient temperature range of -20 °C to 50 °C.

**Model types** – The specific model types addressed by this certificate are as follows:

**Protos Type 3400X and Protos II Type 4400X Modular Measuring System, available with ZU1042.**

**The Protos Type 3400X and Protos II Type 4400X Modular Measuring System consists of the following modules:**

**BASE 3400Xa/b or BASE 4400Xa/b. Power Supply.**

a = Enclosure material C or S;  
b = Power supply option 24V or VPW

**FRONT 3400Xa-015 or FRONT 4400Xa-015. Door.**

a = Enclosure finish C or S.

**Measuring Modules:**

**pH 3400X-03a. pH Module.**

a = pH measurement option 2, 3, 5 or 6

**CO2 3400X-130. Carbon Dioxide Module.**

**COND 3400X-041. Conductivity Module.**

**OXY 3400X-06a. Oxygen Module.**

a = Application option 2, 3, 5, 6 or 7

**FIU 3400X-140-2. Digital Module.**

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: [information@fmaprovals.com](mailto:information@fmaprovals.com) [www.fmaprovals.com](http://www.fmaprovals.com)

# **SCHEDULE**



Canadian Certificate Of Conformity No: FM19CA0127X

PHU 3400X-110. pH Module.  
CONDI 3400X-051. Inductive Conductivity Module.  
COMPA 3400X-081. Interface Module.  
COMFF 3400X-085. Interface Module.  
MS 3400X-160. Digital Module.  
MS 4400X-160. Digital Module.

**Communication Modules:**

OUT 3400X-071. Output Module.  
PID 3400X-121. PID Controller Module.

**13. Specific Conditions of Use:**

1. The Protos Type 3400X and Protos II Type 4400X system may only be configured with the modules identified above.
2. Only the modules identified above shall be used with the Protos Type 3400X and Protos II Type 4400X system.
3. The OXY 3400X Oxygen Module shall not be used in oxygen enriched environments with oxygen concentrations greater than 21% by volume.

**14. Test and Assessment Procedure and Conditions:**

This Certificate has been issued in accordance with FM Approvals Canadian Certification Scheme.

**15. Schedule Drawings**

A copy of the technical documentation has been kept by FM Approvals.

**16. Certificate History**

Details of the supplements to this certificate are described below:

Date	Description
1 <sup>st</sup> December 2020	Original Issue.
16 <sup>th</sup> November 2021	<u>Supplement 1:</u> Report Reference: RR229264 dated 16 <sup>th</sup> November 2021. Description of the Change: Add MS 4400X-160 module.

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA  
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: [information@fmaprovals.com](mailto:information@fmaprovals.com) [www.fmaprovals.com](http://www.fmaprovals.com)